


MESA BLACKOUT & FACADE BLACKOUT

COMMERCIAL PVC FREE



TEXTSTYLE

June 2023

Product Distributor: Rollease Acmeda

Testing Laboratory: Berkley Analytical

Risk Assessor: Labeling Sustainability Inc.

Supplier Declaration of Conformity and Claim of Low voe Content - Mesa Fabric

The voe assessment for the voes off gassed by the fabric Mesa BO 118” Black, referred to for the test as Kit 3, distributed by Rollease Acmeda was tested by Berkley Analytical, in test report number 1135-002-02AMar2219.

Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers Version 1.2 was performed with the intent of determining the state of compliance of the materials for USG BC LEED v4, MR credit for Low Emitting Materials. A complete listing of all fabrics included in the tested system products Kit 3: Mesa BO 118” Black, are detailed in Table 1. All calculations and assumptions are based on the model data that is for predicted voe concentration in air in 30.6 m³ of an indoor environment. For purposes of the report and subsequent calculations it is referred to Private Office {30.6 m³}.

In accordance with the Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers Version 1.2 as prepared by the California Department of Public Health, dated January 2017, Section 8.7.1.5.

“A range of product models, brands and/or styles with varying characteristics may be grouped together for testing purposes if the products can be expected to have virtually the same performance during testing and use. A test group shall only include models which are made using the same production methods and are comprised of the same product ingredients (formulation). The test sample shall be selected from the model in the group that can be expected to give the worst results for the test taking into consideration special attributes, materials, methods of manufacturing, suppliers, etc.” (2)

This allows for the full line of fabrics distributed by Rollease Acmeda to be listed in Table 1. An excerpt from the full reports by Berkeley Analytical, number 1135-002-02A-Mar2219 are included as evidence of the full system tested.

MESA BLACKOUT & FACADE BLACKOUT



TEXSTYLE

COMMERCIAL PVC FREE

Table 1: Fabrics covered by test kit 3, “*” denotes actual fabric tested.

061003000BLA	*Mesa BO 118” Black
061003000BLAF	Mesa BO 118” Black Façade
061003000DOV	Mesa BO 118” Dove White
061003000DUN	Mesa BO 118” Dune
061003000ICE	Mesa BO 118” Ice Gray
061003000MIS	Mesa BO 118” Mist
061003000MOO	Mesa BO 118” Moonstone
061003000NOU	Mesa BO 118” Nougat
061003000PEA	Mesa BO 118” Pearl
061003000QUI	Mesa BO 118” Quill
061003000SEA	Mesa BO 118” Seal
061003000SLA	Mesa BO 118” Slate
061003000SLAF	Mesa BO 118” Slate Façade
061003000STO	Mesa BO 118” Storm
061003000STOF	Mesa BO 118” Storm Façade
061003000TUX	Mesa BO 118” Tuxedo Façade
061003000WHI	Mesa BO 118” White

Leadership in Energy and Environmental Design (LEED)

The USGBC LEED v4 rating system contains a credit EQ Credit: Low Emitting Materials. The intent of this credit is to reduce concentrations of chemical contaminants that can damage air quality, human health, productivity, and the environment (3).

“Building products must be tested and determined compliant in accordance with California Department of Public Health (CDPH) Standard Method v1.1-2010, using the application exposure scenario. The default scenario is the private office scenario. The manufacturer’s or third-party’s certification must state the exposure scenario used to determine compliance.

Manufacturers’ claims of compliance must state the range of total VOCs after 14 days (336 hours), measured as specified in the CDPH Standard Method v1.1:

-0.5 mg/m³ or less; between 0.5 and 5.0 mg/m³ or more.”

The manufactured Fabric Product Kit 3: Mesa BO 118” Black, tested by Berkeley Analytical, in report number 1135-002-02A-Mar2219 are compliant with this low emitting material standard with a 14-day Total VOC of less than 0.5mg/m³. This is based on the modeled scenario for a private office at 30.0 m³. The certificate attached.

Lindsey DeSalvo, Product Manager – Fabrics
TEXSTYLE, a division of Rollease Acmeda

MESA BLACKOUT & FACADE BLACKOUT

COMMERCIAL PVC FREE



TEXTSTYLE



COMPLIANCE TESTED by berkeley analytical


VOC Emission Test Certificate

Product Name: Window Coverings Kit 3 - 061003000BLA

Product Sample Information

Company: Rollease Acmeda
Company Website: www.rolleseaacmeda.com
Product Type: Window Covering (any)
Date Produced: 2/19/2019

Certificate Information

Certificate No: 190322-02
Certified By: 
 Raja S. Tannous, Laboratory Director
Date: March 22, 2019

Reference Standard: California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 (Emission testing method for CA Specification 01350)

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Exposure Scenario ¹	Individual VOCs of Concern ²		Formaldehyde ³		TVOC ⁴
	Criterion	Compliant?	Criterion	Compliant?	Range
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m ³	YES	≤ 0.5 mg/m ³

Product Coverage⁵: Not applicable

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.2-2017)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m³, effective Jan 1, 2012; previous limit was ≤16.5 µg/m³ (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m³, >0.5 – 4.9 mg/m³, and ≥5.0 mg/m³
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

Standards & Codes Recognizing CDPH Standard Method V1.2 (partial list)

- USGBC LEED Version 4, BD&C, ID&C
- The WELL Building Standard

Narrative: Rollease Acmeda selected a sample representative of its Window Coverings Kit 3 - MESA BO 118" Black 061003000BLA polyester product and submitted it on 2/27/2019 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.2-2017. The results of the test are presented in Berkeley Analytical report, 1135-002-02A-Mar2219.

Berkeley Analytical is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

DISCLAIMER: THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE.

MESA BLACKOUT & FACADE BLACKOUT

COMMERCIAL PVC FREE



TEXTSTYLE



VOC Emissions from Building Products

Customer & Building Product Sample Information

Report Certification	
Report number	1135-002-02A-Mar2219
Report date	Mar 22, 2019
Certified by (Name/Title)	Raja S. Tannous, Laboratory Director
Signature	
Date	March 22, 2019

Standards	
Test method	CDPH/EHLB/Standard Method V1.2 (Sect. 01350)
Acceptance criteria	CDPH/EHLB/Standard Method V1.2
Modeling scenario	CDPH/EHLB/Standard Method V1.2 Standard Office
Product type	Window Covering (any)

Customer Information	
Manufacturer or organization	Rollease Acmeda
City/State/Country	Stamford, CT USA
Contact name/Title	Patrick O'Connell, VP Quality
Phone number	6176800300

Product Sample Information*	
Manufacturer (if not customer)	Same as above
Product name / Number	Window Coverings Kit 3 / 061003000BLA
Product CSI category	Window Treatments (12 20 00)
Customer sample ID	MESA
Manufacturing location	Rollease Acmeda Conover NC 28613
Date sample manufactured	Feb 19, 2019
Date sample collected	Feb 20, 2019
Date sample shipped	Feb 26, 2019
Date sample received by lab	Feb 27, 2019
Condition of received sample	No observed problems
Lab sample tracking number	1135-002-02A
Conditioning start date & duration	Mar 1, 2019; 10 days
Chamber test start date & duration	Mar 11, 2019; 4 days (96 hours)
Total test start date & duration	Mar 1, 2019; 14 days (336 hours)

*Chain-of-custody (COC) form for product sample is attached to this report

MESA BLACKOUT & FACADE BLACKOUT

COMMERCIAL PVC FREE



Conformity Assessment – CDPH VOC Concentration Criteria

VOC Emission Test Results – The product sample was tested for emissions of VOCs following California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017. The chamber test results were modeled to one or more scenario(s) defined in CDPH Standard Method V1.2. The modeled indoor VOC concentrations then were compared to the acceptance criteria defined in CDPH Standard Method V1.2 to determine compliance of the product sample to the standard. The modeling scenario(s) are detailed in Table 3, and the predicted indoor VOC concentrations at 336 hours are given in Table 6 of this report. The allowable concentrations used as acceptance criteria are reproduced in Appendix B of this report. Table 1 summarizes the pass/fail results based on the predicted indoor air concentrations of individual VOCs of concern in the modeled scenario(s).

TVOC Concentration Range – USGBC’s LEED v4 rating systems for buildings include a requirement for reporting of the predicted TVOC concentration in one of three range categories, i.e., $\leq 0.5 \text{ mg/m}^3$, >0.5 to 4.9 mg/m^3 , and $\geq 5.0 \text{ mg/m}^3$. Table 1 includes the TVOC concentration range in the modeled scenario(s).


Table 1. Pass/Fail results based on the test method and identified modeling scenario. Only detected individual VOCs with defined acceptance criteria are listed. The TVOC concentration range also is shown

Chemical	CAS No	Allowable Concentration ($\mu\text{g}/\text{m}^3$)	Predicted Private Office Concentration (Pass/Fail)
Formaldehyde	50-00-0	9	Pass
TVOC ^a	--	--	$\leq 0.5 \text{ mg}/\text{m}^3$

^a Reporting of TVOC range is for information only; TVOC is not a Pass/Fail criterion

MESA BLACKOUT & FACADE BLACKOUT

COMMERCIAL PVC FREE



TEXSTYLE

berkeley  analytical



Photographs of Tested Product Specimen

Photo Documentation – The product sample specimen is photographed immediately following specimen preparation and prior to initiating the conditioning period. Typically, the top and bottom faces of the specimen are photographed. Bottom faces may show a stainless steel plate or other substrate if prescribed by the standard.

